

COMPLAINT WATER SAMPLES 14 July 2025 To 14 July 2025

Receive Dated	Type	Agency	Ward	Area	Source Type	Sample ID	Original / Sample No.	Code / Name & Address	Residual Chlorine	Coliform	E. Coli	Oxidase	Results	Remarks
14/07/2025	Complaint	MOH	Ward T	Slum	Tap	B/118348	07181/624	NCWA'S DHANVALLABH ENGLISH HIGH SCHOOL, P.K.ROAD MULUND WEST	0.80	Absent	Absent	Not Applicable	Safe	The sample of Drinking Water conforms to the standards prescribed in IS:10500 of 2012(Reaffirmed 2023) hence bacteriologically safe for drinking purpose for the parameters tested.

Total Water Samples Received 1
Total Unsafe Samples 0
Coliform Positive Samples 0
E. Coli Positive Samples 0
Coliform Positive % 0
E. Coli Positive % 0

UNSAFE SAMPLE :Water quality indicator bacteria Total Coliform Present/100 ml and/or E. Coli Present/100ml